



May 6, 2009

KD ENGINEERING CONSULTANTS  
KEITH E DALSING  
2600 COUNTY RD Y  
DODGEVILLE WI 53533

CONTAINMENT SOLUTIONS  
5150 JEFFERSON CHEMICAL RD  
CONROE TX 77301

Re: Description: SEWAGE TANKS, FIBERGLASS  
Manufacturer: CONTAINMENT SOLUTIONS  
Product Name: HOLDING  
Model Number(s): SWT G-6 (8') 4000 GALS. SINGLE-WALL, FIBERGLASS  
( 8 FT. DIAMETER, 4000 GALLONS MAX. CAPACITY, 84 IN. MAX. DEPTH OF BURY)  
Product File No: 20090187

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of May 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- The manhole cover shall be provided with a locking device that conforms to s. Comm 84.25 (7)(h) of the Wisconsin Administrative Code.
- Access and warning label: Access openings are min. 24 in. diameter and up to 36 in.; available in oval; locking device required when buried less than 6 in. below grade; permanent warning label as per s. Comm 84.25.
- Tank bedding: Use of approved bedding and backfill material is critical; materials must be free of ice and dry; material may be: 1/8 to 3/4 in. clean aggregate or 1/8 to 1/2 in. washed crushed stone or gravel; no more than 5% passing through #8 sieve; else contact manufacturer's technical staff.

**As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov